

MAR 27 1966

RECEIVED JUN 7 1966

well #3

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER STATE OF OREGON WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

State Well No. 5/2w-32R State Permit No. G-3813

(1) OWNER:

Name Oak Crest Farm Address 2270 Wallace Rd Salem, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 5/2W-32R 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

1.23/4" Diam. from 140 ft. to 151 ft. Gage 250

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Mills Size of perforations 3/8 in. by 2 1/2 in. 732 perforations from 117 ft. to 147 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 5/14/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 20 gal./min. with 2 ft. drawdown after 4 1/2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 12 Depth drilled 151 ft. Depth of completed well 151 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Top soil, Clay yellow, Silt, Silt blue, Clay blue, Sand blk, Sand & gravel, Clay sandy, Sand coarse blk with pumice pebbles, Sand & gravel brwn.

Work started 5/5/66 19 Completed 5/14/66 19 Date well drilling machine moved off of well 5/16/66 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm or corporation) (Type or print) Address 2214 Front St NE Salem, Ore.

Drilling Machine Operator's License No. 63

[Signed] Harry A. Robinson (Water Well Contractor)

Contractor's License No. 22 Date 5/23/66, 19