

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
JUN 2 1967
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

MAR 28 1965

State Well No. 5/2w-33c
State Permit No. _____

(1) OWNER: SALEM, OREGON
Name Oak Crest Farm
Address P.O. Box 405
Salem, Ore.

(2) LOCATION OF WELL:
County Marion Driller's well number 5/2W-33C
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED: Threaded Welded
12 3/4 Diam. from 140 ft. to 221 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Mills
Size of perforations 3/8 in. by 2 1/2 in.
648 perforations from 127 1/2 ft. to 150 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Puddled clay
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 14 1/2 ft. below land surface Date 5/31/67
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test 20 gal./min. with 1 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 221 ft. Depth of completed well 221 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Grey clay	0	5
Brown clay	5	12
Brown silty clay	12	23
Blue silty clay	23	66
Muddy blk sand	66	75
Clean blk sand	75	100
Grey clay	100	117
Sand & gravel (water)	117	120
Brown clay	120	127
Sand & gravel (water)	127	129
Gravel with dk grn clay	129	130
Sand & gravel fairly Tight	130	150
Brwn clay & coarse gravel	150	151
Grey & brwn clay	151	160
Muddy fine sand	160	168
Clean blk sand	168	182
Blk sand & gravel	182	183
Black sand	183	200
Sticky grey clay	200	213
Compact coarse sand	213	218
Gravel with clay	218	221

Work started 5/16/67 19 Completed 5/31/67 19
Date well drilling machine moved off of well 6/1/67 19

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Harry A. Robinson (Type or print)
Address 2214 Front S. NE Salem, Ore.
Drilling Machine Operator's License No. 63
[Signed] Harry A. Robinson (Water Well Contractor)
Contractor's License No. 22 Date 6/2/67, 19