

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

28/18
MAY 18

RECEIVED
STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

STATE WELL REPORT
STATE Well No. 55/24-34

(Please type or print)
State Permit No. _____

(Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(1) OWNER:

Name Sawa Kalugin
Address 1129 E. Lincoln St.
Woodburn, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 130 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom Driller
" 100 gal./min. with 20 ft. drawdown after 1 hrs.
" 175 " " 31 " " 1 "
" 250 " " 40 " " 2 "
Bailer test gal./min. with ft drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 41 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 5 sacks
Number of sacks of bentonite used in well seal
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Prugs Size: location " ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
¼ ¼ Section 34 T. 5s R. 2w W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.
Static level 24 ft. below land surface. Date 4-30-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 128 ft. Depth of completed well 128 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay brown	2	27	
Clay blue	27	73	
Clay sand blue med	73	78	
Sand black med.	78	84	
Clay sand blue med.	84	108	
Gravel sand coarse	108	129	

Work started 4-17 1973 Completed 4-30 1973
Date well drilling machine moved off of well 4-30 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] George J. Wanner Date 4-30, 1973
(Drillrig Machine Operator)

Drilling Machine Operator's License No. 837

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name William D. Christenson Jr.
(Person, firm or corporation) (Type or print)
Address P.O. Box 343 Hubbard, Oregon
[Signed] William D. Christenson Jr.
(Water Well Contractor)

Contractor's License No. 511 Date 4-30, 1973