

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
STATE ENGINEER
 JUN 13 1968
STATE OF OREGON
 (Please type or print)
 STATE ENGINEER
 SALEM OREGON

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

State Well No. 5/2w-34
 State Permit No. _____

282
MAR 1968

(1) OWNER:

Name TIMOTHY J. STRUBHAR
 Address 8795 PORTLAND RD. NE. BROOKS OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 10" Diam. from 0 ft. to 175 ft. Gage 4"
 6" Diam. from 0 ft. to 120 ft. Gage 4"

PERFORATIONS:

Perforated? Yes No
 Type of perforator used MILLS
 Size of perforations 3/8 in. by 2 1/2 in.
 150 perforations from 128 ft. to 132 ft.
 150 perforations from 152 ft. to 156 ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Type _____
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 20'9" ft. below land surface Date 6-3-68
 Artesian pressure lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " " " "
 " " " " " "
 Baller test 75 gal./min. with 5 ft. drawdown after 1 hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water 51° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE
 Depth of seal 60' ft.
 Diameter of well bore to bottom of seal 17 1/4" in.
 Were any loose strata cemented off? Yes No Depth 174' TO 184'
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water SANDY depth of strata 174' TO 184'
 Method of sealing strata off CEMENTED
 Was well gravel packed? Yes No Size of gravel: 3/4 ROUND
 Gravel placed from 120' ft. to 135' ft.

(11) LOCATION OF WELL:

County MARION Driller's well number _____
1/4 S.E. 1/4 Section 34 T. 55 R. 2W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 10"
 Depth drilled 184' ft. Depth of completed well 174' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW	2	21	
CLAY BLUE SILTY	21	54	
CLAY BLUE STICKY	54	64	
SAND-FINE-MUDDY	64	86	
CLAY BLUE STICKY	86	88	
CLAY YELLOW	88	98	
CLAY BLUE-SILTY	98	105	
CLAY YELLOW SANDY	105	120	
CONGLOMERATE	120	122	
CLAY BLUE SANDY	122	131	
SAND + PEBBLES 5"	131	132	20'9"
SAND-BLUE-FINE-MUDDY	132	144	
CONGLOMERATE	144	145	
CLAY BLUE STICKY	145	147	
CLAYSTONE-BLUE FIRM	147	152	
CLAYSTONE BLUE-SOFT	152	156	20'9"
DECOMPOSED WOOD + SAND	156	159	
CLAYSTONE FIRM	159	174	
CLAYSTONE-SANDY	174	184	

Work started 5-24 1968 Completed 6-3- 1968
 Date well drilling machine moved off of well 6-3- 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R.F. Sneed Date 6-11- 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS
 (Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM ORE.

[Signed] R.A. Sneed
 (Water Well Contractor)

Contractor's License No. 6 Date 6-11- 1968