

2829 MARI

well # 2

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 25 1967

WATER WELL REPORT

State Well No. 5/2w-34 Q
State Permit No. G-3455, G-7507

STATE ENGINEER, SALEM, OREGON 97310
DATE ENGINEER

STATE OF OREGON (Please type or print) G-3962

(1) OWNER: SALEM OREGON
Name Jim Butsch
Address RT 1 Box 99 Mt Hyle Ore

(2) LOCATION OF WELL:
County Marion Driller's well number
SW 1/4 SE 1/4 Section 34 T. 5S R. 2W W.M.
Bearing and distance from section or subdivision corner
465 FT N & 210 FT W of the
SE Corner of the 1/4 Sec
corner of the SW 1/4 of the SE 1/4
of Sec 34 T 5 S R 2 W 2 W 11

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
12" Diam. from 0 ft. to 228 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used Star H way
Size of perforations 3/8 in. by 1 1/2 in.
10.38 perforations from 1.38 ft. to 15.0 ft.
8.00 perforations from 1.83 ft. to 20.3 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Model No.
Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Grout
Depth of seal 6.0 ft. Was a packer used? No
Diameter of well bore to bottom of seal 15 3/4 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 19 ft. below land surface Date 3-20-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 585 gal./min. with 29 ft. drawdown after 4 hrs.
" 900 " 46 " 3 1/2 "
" " " " " "
Bailer test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing None
Depth drilled 228 ft. Depth of completed well 228 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	3
Brown silt & clay	3	32
Blue silt & clay	32	45
Fine sand & clay (Blue)	45	72
Fine Black sand	72	78
Blue clay & silt	78	107
Plum & gravel & sand	107	115
Brown sand (Medium)	115	126
Coarse sand & gravel	126	136
Coarse gravel some Dark sand	136	148
Green clay	148	158
Blue clay	158	163
Dark silt & sand	163	171
Dark Blue clay	171	178
Gravel Blue clay Binder	178	198
Loose Gravel & sand	198	203
Dark Blue clay (Hard)	203	212
Dark silt & sand	212	227
Fine Gravel	227	228?

Work started 3-1 1967 Completed 3-20 1967
Date well drilling machine moved off of well 3 20 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Beck Well Drilling (Person, firm or corporation) (Type or print)
Address 954 S Ivy St Canby Ore
Drilling Machine Operator's License No.
[Signed] John W Beck (Water Well Contractor)
Contractor's License No. 449 Date 3-20 1967