

MAR 28 1965

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 5/2w-36A State Permit No. 63337

(1) OWNER:

Name CYRIL MOULLET Address RT. 1 BOX 207 GERVAIS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I006 1/4 Section 36 T. 5 S R. 2 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [X] I0 " Diam. from TOP ft. to I05 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No

Type of perforator used MILLS Size of perforations 2 in. by 3/8 in. 200 perforations from 85 ft. to I05 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No

Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal I2 in. Were any loose strata cemented off? [ ] Yes [ ] No Depth Was a drive shoe used? [X] Yes [ ] No Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusuable water? [ ] Yes [ ] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level I0 ft. below land surface Date 2/24/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [ ] No If yes, by whom? DRILLER Yield: 600 gal./min. with 60 ft. drawdown after 8 hrs. " 550 " 48 " 8 " " 400 " 35 " 8 " Perforator 330 gal./min. with 30 ft. drawdown after 8 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled I05 ft. Depth of completed well I05 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL, CLAY, SAND, CLAY, SAND, CLAY, SAND, CLAY, SAND, GRAVEL.

Work started FEB. 16 19 65 Completed FEB 24 1965 Date well drilling machine moved off of well FEB 24 1965 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO. (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM, OREGON Drilling Machine Operator's License No. I79 [Signed] Emil O. Beier (Water Well Contractor) Contractor's License No. 2 Date FEB. 24 1965