

MARI. 2880

RECEIVED

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON
STATE ENGINEER (Please type or print)
SALEM OREGON

JUN 6 1966 WATER WELL REPORT
G-6045
G-3879

36 D
State Well No. 5/2w-28
State Permit No.

(1) OWNER:

Name JAMES MOULLET
Address RT. 1 BOX 198
GERVAIS, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number II40
1/4 Section 26 T. 35-36. 2 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
10" Diam. from TOP ft. to 140 ft. Gage 250

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 2 in. by 3/8 in.
380 perforations from 110 ft. to 135 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 27 ft. below land surface Date 5/18/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 350 gal./min. with 33 ft. drawdown after 26 hrs.
" 500 " " 43 " 28 "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 140 ft. Depth of completed well 140 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
BROWN SANDY SOIL	3	41
BLUE CLAY	41	62
GRAY CLAY	62	99
BLACK SAND	99	107
BLACK SAND & GRAVEL	107	115
BROWN SAND & SOME GRAVEL	115	119
BLACK SAND & LARGE GRAVEL	119	135
BLUE CLAY	135	140

Work started MAY 3 1966 Completed MAY 18 1966
Date well drilling machine moved off of well MAY 18 1966 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 470

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date MAY 18 1966 19