

TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM, OREGON
 within 30 days from the date
 of well completion.

WATER WELL REPORT

RECEIVED
 JUN 3 1968
 STATE ENGINEER
 SALEM, OREGON

2883
 MARI.....
 G-5971
 G-4558

STATE OF OREGON
 (Please type or print)
 Do not write above this line)

State Well No. 5/2w-36M
 State Permit No. bc

(1) OWNER:

Name John Zellner
 Address Rt. 1 Box 150 Gervais, Oregon 97026

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12" Diam. from top ft. to 160 ft. Gage 160
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
 Type of perforator used Mills
 Size of perforations 1/4 in. by 2 1/2 in.
~~5/16~~ 5/16 perforations from 105 ft. to 145 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 23 ft. below land surface Date 5-15-68
 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom Driller
700 gal./min. with 7 ft. drawdown after 4 hrs.
600 " " 5 " " 4 "
 " 500 " " 4 " " 4 "
 Pump test 400 gal./min. with 3 ft. drawdown after 4 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Drill cuttings Puddle clay
 Depth of seal 20 ft.
 Diameter of well bore to bottom of seal 14 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? depth of strata
 Method of sealing strata off
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1313
NW 1/4 SW 1/4 Section 36 T. 5S R. 2W W.M.
 Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing
 Depth drilled 160 ft. Depth of completed well 160 ft.
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	4	
Yellow Clay	4	18	
Silty Yellow Clay	18	50	
Blue Sandy Shale	50	65	
Black sand	65	70	
Sticky Blue shale	70	93	
Sand and fine gravel black	93	100	
Black sand and gravel	100	145	
Soft black sandy shale	145	150	
Black sand	150	152	
Soft black shale	152	158	
Bluish green shale	158	160	23

Work started May 3, 1968 Completed May 15, 1968
 Date well drilling machine moved off of well May 16, 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Arving Bean Date May 16, 1968
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 74

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
 (Person, firm or corporation) (Type or print)

Address 7641 35th ave. NE Salem, Oregon 97303

[Signed] Emil O. Balle
 (Water Well Contractor)

Contractor's License No. 2 Date May 16, 1968