NOTICE TO WATER WELL CONTRACTOR

The original and first copy

filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print)
(Do not write above this line)
STATE ENGANGERNO.
STATE ENGANGERNO.
SALEM OREGON

(1) OWNER:	(11) LOCATION OF WELL:
Name Mrs. Jac F. Mahony	County Marion Driller's well number 1309
Address Rt. 1 Box 281 Gervais, Oregon	14 14 Section 17 T. 58 R. 3W W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well Deepening Reconditioning Abandon	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing
Rotary Driven Domestic Industrial Municipal Domestic	Depth drilled 30 ft. Depth of completed well 30 ft.
Dug Bored I Irrigation Test Well Other	Formation: Describe color, texture, grain size and structure of materials;
CASING INSTALLED: Threaded Welded 2	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
" Diam. from ft. to ft. Gage	MATERIAL From To SWL
	Top Soil 0 2
PERFORA MICHIGA	Top Soil 0 2 Vellow Clay 2 12
PERFORATIONS: Perforated? Yes No.	Gravel 12 30
ype of perforator used 1511s	
Size of perforations 1 in. by 21 in.	
240 perforations from $13\frac{1}{2}$ ft. to 30 ft.	
perforations from	
perforations from	
perforations from	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes 🖻 No	
Manufacturer's Name	
Type	
Diam. Slot size Set from ft. to ft.	
(8) WATER LEVEL: Completed well.	
ft. below land surface Date 5-7-68	
esian pressure lbs. per square inch Date	
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ☐ No If yes, by whom? Driller	
d: 450 gal./min. with 16 ft. drawdown after 8 hrs.	Work started 5_2_68 19 Completed 5_7_68 19
500 " 22 " 8 "	Date well drilling machine moved off of well 5-8-68.
. " " " " "	Drilling Machine Operator's Certification:
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best
Artesian flow g.p.m. Date	knowledge and belief.
Temperature of water Was a chemical analysis made? Yes No	[Signed] Aprilling Machine Operator) [Signed] Aprilling Machine Operator)
(10) CONSTRUCTION:	Drilling Machine Operator's License No536
Well seal-Material used Drill curtings and puddle clay	
Depth of seal 2 13 ft.	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Were any loose strata cemented off? ☐ Yes ☐ No Depth	NAME WILL METTE DRILLING COMPANY (Person, firm or corporation) (Type or print)
Was a drive shoe used? ☐ Yes ☐ No Did any strata contain unusable water? ☐ Yes ☑ No	1
	Address 7641 35th Ave. NE Salem, Oregon 97303
	Prill Raine
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	G-tweeterle T towns No. 2 Date 5-8-68
Gravel placed from ft. to ft.	Contractor's License No2 Date 5-8-68 , 19