

RECEIVED

MARI. 2909

58/3W-13ac

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.785)

JUL 06 1987

(1) OWNER: Name Bill L. Rose Address 17236 Butteville Rd. NE City Woodburn State Oregon Zip 97071

(2) TYPE OF WORK: [X] New Well [] Deepen [] Recondition [] Abandon

(3) DRILL METHOD: [] Rotary Air [] Rotary Mud [X] Cable [] Other

(4) PROPOSED USE: [] Domestic [] Community [] Industrial [X] Irrigation [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 290' ft. Special Standards date of approval

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds. Row 1: 16" 0 to 18 bentonite 0 to 20 28 sacks

How was seal placed? Method [] A [] B [] C [] D [] E [X] Other OAR 690-61-097

(6) CASING/LINER: Diameter From To Gauge Steel Plastic Welded Threaded

Table for casing/liner with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Row 1: 16" 0 to 290' 3.75 3x

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: [X] Perforations Method Mills Knife [] Screens

Table for perforations/screens with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Row 1: 72 284 3/8x3 336

(8) WELL TESTS: Minimum testing time is 1 hour [X] Pump [] Bailer [] Air [] Flowing Artesian

Table for well tests with columns: Yield gal/min, Pumping level, Drift/ft at, Time 1/4 hr. Row 1: 900 172' 1 hr

Temperature of water Depth Artesian Flow Found Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description: County Marion Township 58 N or S, Range 3W E or W, WM. Section 13 SW 1/4 NE 1/4 Street Address of Well (or nearest address) Marthaler Rd.

(10) STATIC WATER LEVEL: 61' ft. below land surface. Date June 16, Artesian pressure lb. per square inch. Date

(11) WELL LOG: Ground elevation

Large table for well log with columns: Material, From, To, WB?, SWL. Rows include Clay Brown, Clay grey, Sandy clay, Clay Grey, Sand Black, Gravel, sand, clay, etc.

Date started May 15, 1987 Completed June 17, 1987

(unbonded) Water Well Constructor Certification: I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

(bonded) Water Well Constructor Certification: I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief. Signed Ivan Grossen Date June 30, 1987 Company Grossen's Well Drilling Job No. 74