

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 56/3w-234dd

State Permit No. 5/3w-34dd

RECEIVED JUL 10 1968 STATE ENGINEER SALEM, OREGON

2931 MAR 1... G 5417

(1) OWNER:

Name Bison Lafallett  
Address Salem Ore

(11) LOCATION OF WELL:

County Marion Driller's well number 105  
Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 99 ft. Gage 14

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used 2 inch  
Size of perforations 1/4 in. by 6 in.  
60 perforations from 40 ft. to 99 ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WATER LEVEL: Completed well.

Static level 20 ft. below land surface Date June 10-68  
Man pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? P. Silber  
Yield: 600 gal./min. with 2 ft. drawdown after 5 hrs.  
Ballor test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used There was already a 12" well cased to 65' with 10" casing mill  
Depth of seal \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Were any loose strata cemented off?  Yes  No  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(12) WELL LOG:

Diameter of well below casing none

Depth drilled 99 ft. Depth of completed well 99 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Entry: Sand & gravel, 65, 99.

The well was already 65' deep and cased with 12"

Work started June 1 19 68 Completed June 5 19 68

Date well drilling machine moved off of well June 5 19 68

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John P. Clow Date 6-17, 19 68  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 464

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Besse Water Drilling  
(Person, firm or corporation) (Type or print)

Address At. 1 Box 75 Dayton Ore

[Signed] Robert Shelburne  
(Water Well Contractor)

Contractor's License No. 417 Date June 17, 19 68