

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

**RECEIVED**  
MAR 28 1969

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON

State Well No. 5/3W-36

within 30 days from the date of well completion. (Please type or print) (Do not write above this line)

State Permit No. \_\_\_\_\_

2953  
MAR 1969

(1) OWNER:

Name Les PEARLINE  
Address Rt. 1 BOX 50  
GERMANS ORR. 97026

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
12" Diam. from 0 ft. to 165 ft. Gage 4  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used MILLS  
Size of perforations 3/8 in. by 2 1/2 in.  
480 perforations from 130 ft. to 152 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WATER LEVEL: Completed well.

Static level 7'5" ft. below land surface Date 2-27-69  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Stetter Supply  
Yield: 500 gal./min. with 25 ft. drawdown after 3/4 hrs.  
580 " 30 " " " "1 "  
700 " 35 " " " "1 "  
Ball test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:

Well seal—Material used MUDDED CLAY  
Depth of seal 46 ft.  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water SANDY depth of strata 102' to 114'  
Method of sealing strata off CASED  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(11) LOCATION OF WELL:

County MARION Driller's well number \_\_\_\_\_  
1/4 Section 36 T. 55 R. 3W W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(12) WELL LOG:

Diameter of well below casing 15"  
Depth drilled 165 ft. Depth of completed well 165 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOPSOIL	0	2	
CLAY YELLOW COLOR	2	48	
SAND FINE - BROWN	48	57	
CLAY BROWN COLOR	57	60	
SAND BROWN FINE	60	71	
CLAYSTONE BLUE	71	78	
CLAYSTONE BROWN	78	90	
CONGLOMERATE	90	102	
CLAY BLUE - SANDY	102	114	
CONGLOMERATE	114	128	
GRAVEL & SAND 1" W.B	128	129	
CONGLOMERATE	129	139	
GRAVEL & SAND 1" W.B	139	140	7'5"
CONGLOMERATE	140	151	
GRAVEL & SAND 75% SAND	151	154	7'5"
CLAYSTONE GRAY FIRM	154	165	

Work started 2-19- 1969 Completed 2-27- 1969  
Date well drilling machine moved off of well 2-27- 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] R.F. Sneed Date 2-27- 1969  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED & SONS  
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. SALEM ORE.

[Signed] R.F. Sneed  
(Water Well Contractor)

Contractor's License No. 6 Date 2-27- 1969