

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

**WATER WELL REPORT**

STATE OF OREGON  
(Please type or print)

**RECEIVED**

FEB 9 1977

State Well No. 55/3W-36

State Permit No. \_\_\_\_\_

(Do not write above this line)

WATER RESOURCES DEPT.

2959  
MARI...

**(1) OWNER:**

Name Lesy Reamire Farms.  
Address 5711 1st St  
Lawson Ore

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Pug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
12" Diam. from 71 ft. to 112 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
588 perforations from 80 ft. to 104 ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Stettler emp.  
750 gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
1450 " 53 " 6 "  
" " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water \_\_\_\_\_ Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Bentonite  
Well sealed from land surface to \_\_\_\_\_ ft.  
Diameter of well bore to bottom of seal 16 in.  
Diameter of well bore below seal 12 in.  
Number of sacks of Bentonite used in well seal 2 sacks  
How was cement grout placed? \_\_\_\_\_  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size/Location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Morrow Driller's well number \_\_\_\_\_  
\_\_\_\_\_ 1/4 Section T. R. W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 25 ft.  
Static level 14 ft. below land surface. Date 1-25-77  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing \_\_\_\_\_  
Depth drilled 120 ft. Depth of completed well 112 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>Brown Clay</u>	<u>0</u>	<u>20</u>	
<u>Sand &amp; Gravel</u>	<u>20</u>	<u>25</u>	
<u>Small to Large Gravel</u>	<u>25</u>	<u>58</u>	
<u>Sand &amp; Gravel</u>	<u>58</u>	<u>70</u>	
<u>Gravel some Sand</u>	<u>70</u>	<u>104</u>	
<u>Blue Grey Clay</u>	<u>104</u>	<u>115</u>	
<u>Quick Sand</u>	<u>115</u>	<u>120</u>	

Work started 1-5 1977 Completed 1-25 1977  
Date well drilling machine moved off of well 1-25 1977

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman Jewell Date 1-26, 1977  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 455

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name EOLA WELL DRILLING  
(Please Print Name of Firm) (Type or print)

Address SALEM, OR 97304

[Signed] Donit D. Berndt  
(Water Well Contractor)

Contractor's License No. 619 Date 1-30, 1977

Stettler Supply Co.

1810 Lana Ave.

Salem, Oregon

5/3W-35  
Marion

WELL TEST CARD

2-18 1969

Well Diameter

12"

Depth

59

Cased to

59

Well straight?

Yes

Depth after pumping

Well casing perforated at

Formation of water bearing strata

Gravel

Test pump setting

48

Length of air line

41

Static level - Before test

9

After test

Static air pressure

Capacity

Pressure on air line

Pumping level

Time

700 GPM

12 Lbs.

13 Feet

1 hr

Minutes

Just Pumping

1/2 hr

800

10

18

Did well clear up?

Yes

RECEIVED

FEB 28 1969

STATE ENGINEER  
SALEM OREGON

Name  
Address

Les Perrine  
Rt #1 Gervin

(WELL BY BRIDGE ON ROAD TO FERRY)

Sec - 35

T - 55

R - 3W

Finished drilling 2-8-69