

MAR 29 1964

RECEIVED
MAY 18 1964
STATE ENGINEER

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

G-6546
G-4345

State Well No. 5/3W-36 H
State Permit No.

(1) OWNER:

Name KENNETH & FRANCIS S. LANDERS
Address RT. 1 BOX 119
GERVAIS, OREGON ZIP 97026

(2) LOCATION OF WELL:

County MARION Driller's well number 917
1/4 Section 36 T. 5 R. 3 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from TOP ft. to 140 ft. Gage 250
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 1/4 in. by 1 in.
282 perforations from 98 ft. to 138 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 70 ft. below land surface Date 5/14/64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 160 gal./min. with 5 ft. drawdown after 3 hrs.
" " " " " " " "
" " " " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 148 ft. Depth of completed well 148 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	20
CLAY	20	60
SAND	60	70
CLAY	70	90
SAND	90	95
GRAVEL	95	138
SAND	138	142
CLAY	142	148

SET PUMP AT 135 FT

Work started MAY 6 1964 Completed MAY 14 1964
Date well drilling machine moved off of well MAY 14 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 179

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date MAY 14 1964