

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT
JAN 16 1968
STATE ENGINEER SALEM, OREGON
RECEIVED
JAN 9 1968
STATE ENGINEER SALEM, OREGON

Well #2
2977
6/1w-1 db
State Well No. 6-4916

(1) OWNER:

Name JAMES BOTSCH
Address R#1 Box 99, Mt Angel, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 384 ft. Gage 330
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 70 ft. below land surface Date 12/19/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 840 gal./min. with 104 ft. drawdown after 13 hrs.
750 " 141 " 1/10/69 1 "
650 " 175 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 59° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT (FROOT)
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County CLATSOP Driller's well number 4296
NE 1/4 SE 1/4 Section 1 T. 65 R. 10 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 12 in to 5 1/2 in
Depth drilled 669 ft. Depth of completed well 669 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
BROWN CLAY	2	19	
CLAY AND GRAVEL	19	29	
BLUE AND GREY CLAY	29	96	
SAND AND CLAY	96	118	
SAND, GRAVEL AND CLAY	118	163	
BLUE SILT	163	203	
STICKY BLUE AND BROWN CLAY	203	277	
CLAY AND SMALL GRAVEL	277	322	
STICKY BROWN CLAY	322	337	
CLAY AND ROCK	337	399	
MED. HARD BLACK BASALT	399	421	
POREUS BLACK BASALT	421	469	
MED HARD BLACK BASALT	469	522	
SOFT BLACK AND RED BASALT	522	530	
BLACK AND BROWN BASALT	530	536	
BLACK POREUS BASALT	536	579	
HARD BLACK BASALT	579	590	
MED HARD BLACK BASALT	590	628	
BROKEN BLACK BASALT	628	637	
HARD BLACK BASALT	637	665	
STICKY GREY AND GREEN CLAY	665	669	

Work started SEPT 18 1968 Completed DEC 26 1968
Date well drilling machine moved off of well DEC 27 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Blowm Rudman Date DEC 28 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 54

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 8110 SE SUNSET LANE PORTLAND, ORE.

[Signed] Robert L. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date DEC 28 1968