

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED

MARI... 2984

JAN 10 1968 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

STATE OF OREGON
(Please type or print)

State Well No. 6/16-1 P3
State Permit No. _____

G 3351

(1) OWNER:

Name Mark Purdy
Address Rte 1 Box 23
Mt. Angel Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
825 ft. N. 2300 ft. E. of S.W. cor of
sec I, T. 6S. R. 1W. of W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded Welded
8" Diam. from 0 ft. to 208 ft. Gage .250
6" Diam. from 200 ft. to 320 ft. Gage .250

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Torch
Size of perforations 3/8 in. by 8 in.
240 perforations from 220 ft. to 310 ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & cuttings
Depth of seal 18 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? No
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 53 ft. below land surface Date 10-26-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller S
Yield: 240 gal./min. with 142 ft. drawdown after 5 hrs.
" " " " " "
" " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water X Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 359 ft. Depth of completed well 359 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|---------------------------|------|-----|
| Top soil, brn. | 0 | 1 |
| Clay, grey. | 1 | 55 |
| Clay, brn. | 55 | 85 |
| Clay, grey, sandy. | 85 | 110 |
| Clay, grey, sticky. | 110 | 140 |
| Clay, brn. | 140 | 205 |
| Sandstone, brn, med hard. | 205 | 230 |
| Claystone, grey, hard. | 230 | 245 |
| Claystone, brn, med. | 245 | 254 |
| Claystone, grey, hard. | 254 | 270 |
| Sandstone, brn, med. | 270 | 310 |
| Claystone, grey, soft. | 310 | 320 |
| Basalt, black, med hard. | 320 | 353 |
| Basalt, black, hard. | 353 | 359 |

Work started 8 - 13 1965 Completed 10 - 26 1965
Date well drilling machine moved off of well 10 - 27 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadelii & Sons
(Person, firm or corporation) (Type or print)
Address RT # 3, Box 169, Silverton, Ore

Drilling Machine Operator's License No. 84. 16.

[Signed] Paul R. Stadelii
(Water Well Contractor)

Contractor's License No. 296 Date 11 - 20 1965