

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

RECEIVED  
OCT 3 1966

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

2986  
MARI.....86

State Well No. 6/1w-1 P2

State Permit No. ....

(1) OWNER:

Name Raymond Knori  
Address Rte. 1, Box 21  
Mt. Angel, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number  
Bearing and distance from section or subdivision corner  
~~1575 ft. east & 250 ft. north from S.W. corner of section 1, T.6 S., R.1 W., of W.M.~~  
1575 ft. east & 250 ft. north from S.W. corner of section 1, T.6 S., R.1 W., of W.M.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

6 " Diam. from 110 ft. to 324 ft. Gage .250  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name ..... Model No. ....  
Type ..... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & Drilling Cuttings  
Depth of seal orig. 35 ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 10 in.  
Were any loose strata cemented off?  Yes  No Depth .....  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Type of gravel: #2 rd.  
Gravel placed from 140 ft. to 110 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... depth of strata .....  
Method of sealing strata off .....

(10) WATER LEVELS:

Static level 95 ft. below land surface Date 7/15/66  
Artesian pressure ..... lbs. per square inch Date .....

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom Drillers  
Yield: 160 gal./min. with 80 ft. drawdown after 3 hrs.  
" 120 " 43 " 3 "  
" 60 " 18 " 3 "  
Baller test XX gal./min. with X ft. drawdown after X hrs.  
Artesian flow XX g.p.m. Date XX  
Temperature of water XX Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6  
Depth drilled 373 ft. Depth of completed well 373 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
clay-brown mixed with #2 gravel that was put in well in 1962-	105	140
Clay-brown	140	155
Clay-grey	155	170
Sandy clay-brown approx. 20 gpm. around 175 but to sandy & muddy.	170	180
Sandy clay-brown	180	240
Clay with mixed colors brown, grey & green	240	321
Claystone soft-grey	321	324
Claystone grey-med. hard	324	328
Basalt-blueish grey-med. hd.	328	345
" " " hard	345	354
Silica jell-glassy brown-	354	355
Basalt greyish br. med. hard	355	358
Silica jell-glassy brown	358	360
Basalt-greyish br. med hard	360	373
Water is coming in the last	13	ft.

Work started 7/4/66 19 Completed 7/16/66 19  
Date well drilling machine moved off of well 7/16/66 19

(13) PUMP:

Manufacturer's Name Universal  
Type: Submersible H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons  
(Person, firm or corporation) (Type or print)  
Address Rte. 3, Box 169, Silverton, Oregon

Drilling Machine Operator's License No. 16 & 84

[Signed] Paul R. Stadel  
(Water Well Contractor)

Contractor's License No. 296 Date 9/28/66, 19.....