

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

DEC 14 1964 WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. 6/1W-4H
 State Permit No. _____

3034
 MARI.....

G 34 58

(1) OWNER:

Name John Singler
 Address Rte. 1, Box 183
Mt. Angel, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
 1/4 Section _____ T. _____ R. _____ W.M. _____
 Bearing and distance from section or subdivision corner
2400 ft. south & 1200 ft. west from
N.E. corner of section 4, T. 6 S., R. 1 W.
of W.M.

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 8" above surface ft. to 48'-05" ft. Gage .250
 " Diam. from surface ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Concrete & Bentonite
 Depth of seal 32 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 9 1/2 in.
 Were any loose strata cemented off? Yes No Depth 30 to 95
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 62 ft. below land surface Date 8/10/64
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 50 gal./min. with 13 ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 " " " " " "
 Bailer test 50 gal./min. with 13 ft. drawdown after 1 hr.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
 Depth drilled 177 ft. Depth of completed well 174 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil brown	0	2
Clay brn.	2	10
Boulders grey brn.	10	14
Med conglomerate grey	14	48
Hard basalt rock grey, fract.	48	98
Clay seam soft grey	98	99
Hard basalt grey fractured	99	177
All water coming in rock		

Work started 7/20 1964 Completed 8/10 1964
 Date well drilling machine moved off of well 8/19 1964

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons (Type or print)
 (Person, firm or corporation)
 Address Rt. 3 Box 169, Silverton, Oreg.

Drilling Machine Operator's License No. 16

[Signed] Paul R. Stadel
 (Water Well Contractor)

Contractor's License No. 296 Date 12/10 1964