

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

RECEIVED
MAY 27 1968

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON (Please type or print)
within 30 days from the date of well completion. SALEM, OREGON Do not write above this line)

3053
MARI...53
G-4495

State Well No. 6/1w-6 L
State Permit No.

(1) OWNER:

Name JOE DANIELS
Address BOX 10602 HOWELL PRAIRIE RD. BROOKS STATION
SALEM, OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 192 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used MILLS
Size of perforations 3/8 in. by 2 1/2 in.
300 perforations from 166 ft. to 179 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 15 ft. below land surface Date 5/23/68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom SPETTNER'S
640 gal./min. with 51 ft. drawdown after 1 hrs.
810 " " 58 " " I " "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used FUDDLE CLAY
Depth of seal 25 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County MARION Driller's well number
1/4 1/4 Section 6 T. 6 R. WEST W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing
Depth drilled 192 ft. Depth of completed well 192 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	5	
Bv. Clay	5	30	
Bv. Sand	30	40	
Blue Clay	40	55	
Dry Sand	55	65	
Blue Clay	65	85	
Brown clay	85	98	
Black Sand	98	135	
Bl. Sand & gravel	135	140	
Dry Corn Husk	140	165	
Gravel	165	180	
Blue Clay	180	192	

Work started MAY 15 1968 Completed 5/23 1968
Date well drilling machine moved off of well MAY 21 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Terrell Date 5/23 1968
(Drilling Machine Operator)
Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. F. Terrell (Type or print)
Address RT #1, Box 57 Gervens, Ore.
[Signed] Miss. Joan D. Terrell (Water Well Contractor)
Contractor's License No. 460 Date 5/23 1968