

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print)
Do not write above this line)

State Well No. 6/1w-766

State Permit No. _____

RECEIVED
MAY 22 1968

G 538 water right in name of Clara Johnson

3059
MAR 19 1968

(1) OWNER: **STATE ENGINEER OREGON**
Name RALPH LEBER
Address P.O. BOX 9097 SALEM ORE.

(11) LOCATION OF WELL:
County MARION Driller's well number _____
1/4 Section 7 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

(12) WELL LOG: Diameter of well below casing 10"
Depth drilled 193' ft. Depth of completed well 193' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

CASING INSTALLED: Threaded Welded
10" Diam. from 0 ft. to 193 ft. Gage 1/4"

MATERIAL	From	To	SWL
TOPSOIL	0	3	
CLAY YELLOW	3	23	
SAND FINE-GRAIN. BLACK	23	37	
CLAY YELLOW STICKY	37	43	
CLAY YELLOW HEAVY	43	60	
CLAY STONE-BLUE-FIRM	60	78	
SAND-MUDDY-BLACK-FINE	78	102	
CONGLOMERATE	102	110	
GRAVEL & SAND 1"	110	112	
CONGLOMERATE	112	119	
GRAVEL & SAND 1"	119	121	
CLAY SILTY BLUE	121	130	
GRAVEL & SAND 1"	130	132'6	
CONGLOMERATE	132'6	138	
GRAVEL & SAND 1 1/2"	138	139	
CONGLOMERATE	139	154	
CLAYSTONE GRAY FIRM	154	158	
SAND-BLACK FINE-MUDDY	158	166	
CONGLOMERATE	166	172	
CLAY BLUE-STICKY	172	178	
CLAY BLUE HEAVY	178	183	
CONGLOMERATE	183	193	

PERFORATIONS: Perforated? Yes No.
Type of perforator used MILLS
Size of perforations 3/8 in. by 3" in.
110 perforations from 113' ft. to 119' ft.
210 perforations from 138 ft. to 154 ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.
Static level 6' ft. below land surface Date 5-18-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STERLING SUPPLY
Yield: 420 gal./min. with 43 ft. drawdown after 1 hrs.
550 " 54 " " 1 "
700 " 65 " " 1/2 "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 51° Was a chemical analysis made? Yes No

(10) CONSTRUCTION:
Well seal—Material used BENTONITE
Depth of seal 50' ft.
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? SANDY depth of strata 78 TO 102
Method of sealing strata off CASED 158 TO 166
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

Work started 5-6- 1968 Completed 5-18 1968
Date well drilling machine moved off of well 5-18- 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] R.T. Sneed Date 5-18, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 187

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J.A. SNEED & SONS
(Person, firm or corporation) (Type or print)
Address 3910 SILVERTON RD. N.E. SALEM ORE.
[Signed] R.T. Sneed
(Water Well Contractor)
Contractor's License No. 6 Date 5-18, 1968