

3061
MARI...

WATER WELL DRILLERS REPORT
STATE OF OREGON

Do Not State Well No. 91W-7 G(1)
Fill In App 6433
State Permit No. 6307

(1) OWNER:

Name William Uppendahl
Address Gervais, Oregon

(2) LOCATION OF WELL: App 433

County Marion Owner's number, if any—
R. F. D. of Street No.

Bearing and distance from section or subdivision corner Well is located
68.66 chs. West and 190 ft. North of the S.E.
corner of William Parker D.L.C. # 49 in
the S.W. 1/4 of N.E. 1/4 of Sec. 7, Tsp. 6 S.
Range 1 West of Willamette Meridian, .

(3) TYPE OF WORK (check):

New well Deepening Reconditioning Abandon
abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:

Rotary
Cable
Dug Well

(6) CASING INSTALLED:

Threaded Welded

FROM	ft. to	ft.	Diam.	Gage OF Wall
Top	to	142	8"	.277
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"
"	"	"	"	"

If gravel packed

Diameter of Bore	from ft.	to ft.
"	"	"
"	"	"
"	"	"
"	"	"
"	"	"

Type and size of shoe or well ring

Size of gravel:

Describe joint welded Spring Steel 3/8 X 2

(7) PERFORATIONS:

Type of perforator used Mills

SIZE	of perforations	in., length, by	in.
FROM	ft. to	ft. perf per foot	No. of rows
141	up to 133"	20 "	7 "
"	"	"	"
"	"	"	"
"	"	"	"

SCREENS: No Screens

Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:

Puddled Clay
Was a surface sanitary seal provided? Yes No To what depth 20 ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata

METHOD OF SEALING

(9) WATER LEVELS:

Depth at which water was first found 78 ft.
Standing level before perforating 45 ft.
Standing level after perforating 45 ft.

Log Accepted by:

[Signed] Wm. J. Uppendahl Dated Sept. 27, 1956
owner

(10) WELL TESTS: Irving Sears Lit.# 8

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. draw down after hrs.
" " " " " "
" " " " " "
*****Pump Test Below*****
Artesian flow g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test g.p.m. with ft. drawdown
Temperature of water 55 Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(11) WELL LOG:

Diameter of well, inches. 8
Total depth 142 ft. Depth of completed well 141 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Top	to	ft.	Top	Soil
4	20	"	Silty yellow clay	
20	56	"	Sandy yellow clay	
56	78	"	Blue clay	
78	89	"	Black sand (Water)	
89	95	"	Brown clay	
95	105	"	Gray & Black Sand	
105	113	"	Brown Sand	
113	120	"	Blue Clay	
120	129	"	Black Sand (Water)	
129	142	"	Black Sand & Gravel (Water)	
142	?	"	Blue Clay	

*****Pump Test*****

Water Table	45 ft.
470 G.P.M.	@ 100 ft 55 ft DD
450 " "	@ 96 ft. 51
380 " "	@ 93 48
340 " "	@ 88 43
300 " "	@ 86 41
178 " "	@ 63 18
140 " "	@ 60 15

These tests were taken after 4 hours pumping

Ground elevation at well site 185 feet above mean sea level.

Work started August 25 56 Completed Sept. 19 19 56

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Irving Sears
(Person, firm, or corporation) (Typed or printed)

Address R.F.D. Gervais, Oregon

Driller's well number 303

[Signed] Irving Sears
(Well Driller)

License No. 8 Dated Sept. 20,, 1956