

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
MAY 27 1964
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

3091
MARI...

State Well No. 6/1W-9
State Permit No. _____

(1) OWNER:

Name JOHN + ANNA SEVERIN
Address RT-1 BOX 166
MT. ANGEL ORR

(2) LOCATION OF WELL:

County MARION Driller's well number _____
1/4 Section 9 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 109 ft. Gage 1/4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 3/8 in. by 3" in.
920 perforations from 38 1/2 ft. to 105 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
Depth of seal 37' ft. Was a packer used? YES
Diameter of well bore to bottom of seal 14" in.
Were any loose strata cemented off? Yes No Depth 20' TO 37'
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 2' + ft. below land surface Date 5-21-64
Artesian pressure 1 # lbs. per square inch Date 5-21-64

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level SETTLER SUPPLY
Was a pump test made? Yes No If yes, by whom?
Yield: 300 gal./min. with 38 ft. drawdown after 1 hrs.
" 450 " 48 " 1 "
" 590 " 82 " 1 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 55 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 110 ft. Depth of completed well 110 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	0	1
CLAY BLUE COLOR	1	2
CLAY YELLOW COLOR	2	9
CLAY BLUE SANDY	9	13
CONGLOMERATE-COBBLESTONE	13	50
GRAVEL W.B. COARSE	50	53
CONGLOMERATE-COBBLESTONES	53	71
GRAVEL W.B. COARSE	71	73
CONGLOMERATE - W.B.	73	108
CLAY BLUE COLOR. STICKY	108	110

NECESSARY TO GROUT CASING BECAUSE OF ARTESIAN FLOW OF 30 G.P.M. AT GROUND LEVEL.

Work started 5-14-1964. Completed 5-21-1964
Date well drilling machine moved off of well 5-21-1964

(13) PUMP:

Manufacturer's Name _____
Type: TURBINE H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED + SONS
(Person, firm or corporation) (Type or print)

Address 3910 SILVERTON RD. N.E. SALEM, O.

Drilling Machine Operator's License No. 187

[Signed] J.A. Sneed
(Water Well Contractor)

Contractor's License No. 6 Date 5-25-1964