

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED OCT 3 1966

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

3093 MAR 1966

State Well No. 6/142-9

State Permit No.

bcc

(1) OWNER:

Name Mr. John Grealish
Address Rte. 1, Box 169 Mt. Angel, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number
Bearing and distance from section or subdivision corner
1475 ft. & 1000 ft. W. of N.E. corner of Sec. 9, T. 6 S., R. 1 W. of W.M.

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [x] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 1' above 100 ft. to 156 ft. Gage .250
6" Diam. from 92 ft. to 156 ft. Gage .250

(7) PERFORATIONS:

Perforated? [x] Yes [] No
Type of perforator used Torch
Size of perforations, 1/2 in. by 6 & 12 in.
68-12 perforations from 50 ft. to 100 ft.
84-6 perforations from 92 ft. to 156 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 37 ft. Was a packer used? Gravel
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? [x] Yes [] No Depth
Was a drive shoe used? [] Yes [x] No
Was well gravel packed? [x] Yes [] No Size of gravel: #2 rd.
Gravel placed from 37 ft. to 50 ft.
Did any strata contain unusable water? [] Yes [x] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 36 ft. below land surface Date 6/10/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom? Drillers
Yield: 100 gal./min. with 30 ft. drawdown after 3 1/2 hrs.
" 350 " 104 ft. " 3 1/2 "
Bailer test 35 gal./min. with 9 ft. drawdown after 1 hr
Artesian flow XX g.p.m. Date
Temperature of water XX Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Table with columns: MATERIAL, FROM, TO. Rows include Top soil-brown, Clay-brown, Clay-grey, etc.

Work started May 11, 1966 Completed June 10, 1966
Date well drilling machine moved off of well June 10, 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
Address Rte. 3, Box 169, Silverton, Oregon

Drilling Machine Operator's License No. 16

[Signed] Paul R. Stadel (Water Well Contractor)

Contractor's License No. 296 Date 6/27/66