

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

NOV 29 1962 WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON (Please type or print) STATE OF OREGON ENGINEER

State Well No. 6/1W-9E1

State Permit No.

3/10/1 MARI.../

(1) OWNER:

Name DR. C. J. EBNER
Address Rt. 1 Box 164
MT. ANGEL ORE

(2) LOCATION OF WELL:

County MIFERON Driller's well number
1/4 1/4 Section 9 T. 6 S R. 1 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 100 ft. Gage 34"
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used MILLS
Size of perforations 5/16 in. by 2 1/2 in.
610 perforations from 46 ft. to 97 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT
Depth of seal 44' ft. Was a packer used? yes
Diameter of well bore to bottom of seal 12" in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 1' ft. below land surface Date 5-10-61
Artesian pressure 2 lbs. per square inch Date 5-10-61

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level STOPPLER SUPPLY
Was a pump test made? [X] Yes [] No If yes, by whom?
Yield: 300 gal./min. with 20 ft. drawdown after 1 hrs.
500 " 33 " 1 "
700 " 38 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55° Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 100' ft. Depth of completed well 100' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include TOPSOIL, CLAY YELLOW COLOR, CONGLOMERATE BOULDERS, GRAVEL COARSE, CONGLOMERATE BOULDERS, GRAVEL SAND 1", CONGLOMERATE BOULDERS, GRAVEL LOOSE 3" W.B, CONGLOMERATE 3".

ARTESIAN AT 67' TO 68' 2" HEAD PRESSURE
ARTESIAN AT 94' TO 95' 2" HEAD PRESSURE
ALL CONGLOMERATES AS LISTED ABOVE SEEM TO BE WATER BEARING

Work started 5-2-1961 Completed 5-10-1961
Date well drilling machine moved off of well 5-10-1961

(13) PUMP:

Manufacturer's Name
Type: TURBINE H.P. 10

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J.A. SHEED & SONS
Address 3910 SILVERTON RD. NE. SALEM O.
Drilling Machine Operator's License No. 187
[Signed] J.A. Sheed
Contractor's License No. 6 Date 5-10-1961