

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 6/1w-12B State Permit No.

RECEIVED JUL 20 1964 MARI... 3/51

(1) OWNER: Name Erwin Nickodemus Address Rte. 1, Box 234 Mt. Angel, Oregon

(2) LOCATION OF WELL: County Marion Driller's well number 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner 2800 ft. east & 350 ft. south from N.W. corner of Sec. 12, T.6 S., R.1 W. W.M.

(3) TYPE OF WORK (check): Well [ ] Deepening [x] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic [x] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [x] 8" Diam. from 0 ft. to 250-? ft. Gage .279 6" Diam. from 274 ft. to 317 ft. Gage .250

(7) PERFORATIONS: Perforated [x] Yes [ ] No Type of perforator used 6" pipe is perforated with Size of perforations 3/8 in. by 6 in. torch. 20 perforations from 274 ft. to 285 ft. 57 perforations from 295 ft. to 317 ft.

(8) SCREENS: Well screen installed? [ ] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal Puddled clay Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [ ] Yes [x] No Depth Was a drive shoe used? [x] Yes [ ] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusuable water? [ ] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 77 ft. below land surface Date 6/11/64 Artesian pressure lbs. per square ch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? Driller Yield: 300 gal./min. with 61 ft. drawdown after 8 hrs. " 200 " 41 " 8 " " 100 " 23 " 8 " Bailer test 35 gal./min. with 18 ft. drawdown after 8 hrs. before liner was installed.

Temperature of water XX Was a chemical analysis made? [ ] Yes [x] No

(12) WELL LOG: Diameter of well below casing 6 Depth drilled 334 ft. Depth of completed well 334 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Clay-grey-firm-water, Clay-greyish-br.-soft & sticky, Basalt-porous-greyish-br. med.-hard, water bearing-, Basalt-blue-very hard, Basalt-blueish-grey-med.hard-Water bearing., Basalt-blueish-grey-very hard, Water-from-317 to 325, Water level seemed to raise some each day. When we started redrilling it was 103 ft. & 77ft. when we finished.

Work started May 26, 1964. Completed June 13, 1964 Date well drilling machine moved off of well June 15, 1964

(13) PUMP: Manufacturer's Name Jacuzzi Type: Submersible H.P. 5

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadeli & Sons (Person, firm or corporation) (Type or print) Address Rte. 3, Box 169, Silverton, Oregon

Drilling Machine Operator's License No. 16

[Signed] Paul G. Stadeli (Water Well Contractor)

Contractor's License No. 296 Date July 9, 1964