

The original and first copy of this report are to be filed with the

RECEIVED JUN 15 1971 STATE OF OREGON

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE ENGINEER SALEM OREGON (Do not write above this line)

(Please type or print)

State Well No. 6/1W-17bcab State Permit No.

(1) OWNER:

Name Leonard Seifer Address 10542 Saratoga Drive Salem, 97305

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

CASING INSTALLED:

8" Diam. from top ft. to 216 ft. Gage 250

PERFORATIONS:

Type of perforator used Mills Size of perforations 3/8 in. by 2 in. 600 perforations from 216 ft. to 112 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No Yield: 150 gal./min. with 50 ft. drawdown after 4 hrs. 220 " 75 " 4 " Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal-Material used Cement and Puddle Clay Well sealed from land surface to 20 ft. Diameter of well bore to bottom of seal 10 in. Diameter of well bore below seal 8 in. Number of sacks of cement used in well seal 6 sacks Number of sacks of bentonite used in well seal Brand name of bentonite Number of pounds of bentonite per 100 gallons of water Ibs./100 gals. Was a drive shoe used? [X] Yes [] No Plug Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 1553 1/4 Section 17 T. 6 R. 1W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 95 ft. Static level 30 ft. below land surface. Date 6-8-71 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing Depth drilled 216 ft. Depth of completed well 216 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Top Soil, Brown clay, Blue Clay, Black sand, Cemented gravel, Brown sand, Large Gravel, etc.

Work started May 8, 1971 Completed June 8, 1971 Date well drilling machine moved off of well June 8, 1971

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Lawrence Vehr Date June 9, 1971 Drilling Machine Operator's License No. 705

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name WILLAMETTE DRILLING COMPANY Address 7641 35th Ave. NE Salem, Oregon 97303 [Signed] Emil O. Beier Date June 9, 1971 Contractor's License No. 2