

RECEIVED

OBSERVATION WELL WATER WELL REPORT STATE OF OREGON

3232 MAR 1959

9/W-18D(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JUL 27 1959

State Well No.

State Permit No.

(1) OWNER:

STATE ENGINEER SALEM OREGON

Name JAMES HOLLEKI Address

(2) LOCATION OF WELL:

County Marion Owner's number, if any - 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 1 ft. to 161 ft. Gage 24" Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No

Type of perforator used MILLS SIZE of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No

Manufacturer's Name Type Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Siz of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [] No To what depth? 10" ft. Material used in seal - PUMP Did any strata contain unusable water? [X] Yes [] No Type of water? SANDY Depth of strata 102' to 127' Method of sealing strata off CASED

(10) WATER LEVELS:

Static level 37' ft. below land surface Date 6-27-59 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] James Holleki 6-27-1959 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? - SUPPLY Yield: 500 gal./min. with 70' ft. drawdown after 1 hrs. 300 " 46' " 1 " 140 " 18' " 1 "

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 55 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well 8" 1-0 inches.

Depth drilled 161' ft. Depth of completed well 161' ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include TOPSOIL, CLAY YELLOW-SANDY, CLAY BLUE SANDY, CLAY BLUE STICKY, MUCKY SAND W-B, CLAY YELLOW-STICKY, MUCKY SAND-YELLOW, SAND BROWN-MEDIUM, SAND + GRAVEL-MUDDY, CEMENTED GRAVEL, WATER GRAVEL #3, CEMENTED GRAVEL.

Work started 6-21 1959 Completed 6-27-1959

(13) PUMP:

Manufacturer's Name Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SHEPARD & SONS (Person, firm, or corporation) (Type or print)

Address 2505 BROOKS ST SALEM

Driller's well number

[Signed] J.A. Shepard (Well Driller)

License No. 6 Date 6-27-1959