NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

32-40 MARI. G6745

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED MAY 8 1974 STATE ENGINEER SALEM, OREGON

State Well No. 6S/1W-19cdc
State Permit No.

(1) OWNER:
Name Rubin Ritchey
Address R2 Box 210 Silverton Ore.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
12" Diam. from +1 ft. to 171 ft. Gage .259
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Mills
Size of perforations 3/8 in. by 2½ in.
192 perforations from 85 ft. to 93 ft.
264 perforations from 112 ft. to 123 ft.
288 perforations from 148 ft. to 160 ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Natural
Number of pounds of bentonite per 100 gallons of water 30 lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 19 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 70 ft.
Static level 35 ft. below land surface. Date 5-1-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled ft. Depth of completed well ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown Clay	0	24	
Blue Sandy Clay	24	51	
Gray Clay	51	70	
Packed Sand	70	77	
Cemented Gravel	77	81	
Small & med Gravel	81	85	
Clay & Gravel	85	88	
Small & med Gravel	88	95	
Sand Some Gravel	95	107	
Small to Large Gravel	107	123	
Clay & Gravel	123	128	
Sand	128	143	
Med & large Gravel	143	153	
Cemented Gravel	153	171	

Work started 4-17 1974 Completed 5-1 1974
Date well drilling machine moved off of well 5-1 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Norman A Terrell Jr. Date 5-3, 1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ROBINSON'S FOLA WELL DRILLING
(Person, firm, or corporation) (Type or print)
Address 4510 BALLS FERRY RD., SALEM, OREGON
[Signed] George H. Robinson
(Water Well Contractor)
Contractor's License No. 13 Date 5-6, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119