

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion

STATE OF OREGON
(Please type or print)

State Well No. 6/14-19 P
State Permit No. _____

3254
MAR 1965

NOV 22 1965
STATE ENGINEER
SALEM OREGON

(1) OWNER: SALEM OREGON

Name Lynn Schaap
Address Route 2, Box 213, Silverton, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
1100 ft. n., 2250 ft. e., of s.w. cor
Sec 19, T. 6s, R. 1W of W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
8.75" Diam. from 0 ft. to 180 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills
Size of perforations 3/4 in. by 2 1/2 in.
315 perforations from 95 ft. to 130 ft.
198 perforations from 136 ft. to 178 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used? Yes
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 29 ft. below land surface Date 10-30-65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 200 gal./min. with 55 ft. drawdown after 1 hrs.
" 300 " " 140 " 2 "
" " " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____

Depth drilled 180 ft. Depth of completed well 180 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	1
Clay brn.	1	13
Clay grey, sandy & sticky	13	52
Med sand, grey.	52	71
Med sand, grey.	71	77
Med congl, hard. brn.	77	81
Med sand, soft, brn.	81	83
Med congl, hard.	83	134
Med Loose gravel w.b.	134	136
Med congl. w.b.	136	139
Med sand, grey.	139	146
Med congl, grey. w. b.	146	160
Loose gravel. w. b.	160	165
Med congl. w. b.	165	168
Loose gravel. w. b.	168	180

Work started 10-21 19 65 Completed 10-30 19 65
Date well drilling machine moved off of well 10-2 19 65

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
(Person, firm or corporation) (Type or print)

Address Route 3, Box 169, Silverton, Ore

Drilling Machine Operator's License No. 84. 322.

[Signed] Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 11-11, 19 65