

RECEIVED
OCT 6 1960

MAR 3 2 55

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE ENGINEER STATE OF OREGON

State Well No. 6/10-19 R
State Permit No. G2375

(1) OWNER: SALEM, OREGON
Name ROY W. FISKE
Address Rt. 2 BOX 168 SILVERTON ORE

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
8" Diam. from 0 ft. to 101' ft. Gage 4"

(7) PERFORATIONS:
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft. 8" +
Was a surface seal provided? Yes No To what depth? 8" + ft.
Material used in seal— PUMP COVERED
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off CEMENT + BACKFILLED

(10) WATER LEVELS:
Static level 30 ft. below land surface Date 8-30-60
Artesian pressure lbs. per square inch Date

Log Accepted by: [Signature]
[Signed] Date 8-30-1960 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stiller Sup.
Yield: 55 gal./min. with 50 ft. drawdown after hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 8" inches.
Depth drilled 101' ft. Depth of completed well 101' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
WILLAMETTE SILT	0	3
YELLOW CLAY	3	21
BLUE CLAY - SANDY	21	65
MUCKY SAND	65	78
CEMENTED GRAVEL	78	81
WATER GRAVEL #1"	81	81'6"
CEMENTED GRAVEL	81'6"	90'6"
WATER GRAVEL	90'6"	91
CEMENTED GRAVEL	91	100'
WATER GRAVEL #2 1/2"	100	101

Work started 8-27-60 Completed 8-30-1960

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME J.A. SNEED + SONS (Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST - SALEM ORE
Driller's well number
[Signed] J.A. Sneed (Well Driller)
License No. 6 Date 8-30-1960