

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

RECEIVED

NOV 22 1965 WATER WELL REPORT

3288
MARI...

STATE ENGINEER, SALEM, OREGON
within 30 days from the date of well completion.

State Well No. 6/100-21 Q
State Permit No.

(1) OWNER:

Name Harold Kloster
Address Rt # 3, Box Rte. 2, Silverton, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number
Bearing and distance 2450 section or subdivision corner
900 ft N, 200 ft W, of S.E. cor, of sec 21, T6S, R1W, of W.M.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 125 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Mills
Size of perforations 1/4 in. by 3 in.
64 perforations from 70 ft. to 75 ft.
488 perforations from 83 ft. to 124 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & cuttings
Depth of seal 20 35 ft. Was a packer used? Yes
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 33 ft. below land surface Date 10-19-65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with " ft. drawdown after " hrs.
" " " " "
" " " " "
" " " " "
Bailer test 50 gal./min. with 5 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 130 ft. Depth of completed well 130 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil.	0	1
Clay, grey.	1	25
Clay, blue grey.	25	39
Course congl., grey.	39	43
Med congl., grey.	43	49
Clay, brn.	49	57
Sandy clay, with wood, grey.	57	66
Med congl., med hard, W.B.	66	76
Sandy clay, soft, grey.	76	78
Med congl., med hard, W.B.	78	95
Med congl., soft, grey, W.B.	95	100
Med congl., hard, grey, W.B.	100	125
Clay, firm, grey.	125	130

Work started 10-5 1965 Completed 10-19 1965
Date well drilling machine moved off of well 10-20 1965

(13) PUMP:

Manufacturer's Name ?
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadeli & Sons
(Person, firm or corporation) (Type or print)
Address Rt # 3, Box 169, Silverton, Oregon
Drilling Machine Operator's License No. I6
[Signed] Paul R. Stadeli
(Water Well Contractor)
Contractor's License No. 296 Date 11-13 1965