NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAY 15 1972 STATE ENGINEER SALEM, OREGON

MARI 3390

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 6/1W-26 bd
State Permit No.

(1) OWNER:
Name David Scharer
Address Rt 1 Box 90 B Silverton, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 101 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used —
Size of perforations — in. by — in. —
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom? —
Yield: — gal./min. with — ft. drawdown after — hrs.
" " "
" " "
Bailer test 36 gal./min. with 43 ft. drawdown after 1 hrs.
Artesian flow — g.p.m. —
Temperature of water 54 Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal — sacks
Number of sacks of bentonite used in well seal 2 sacks
and name of bentonite National
Number of pounds of bentonite per 100 gallons of water 100 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? — depth of strata —
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: —
Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
SE ¼ NW ¼ Section 26 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 45 ft.
Static level 8 ft. below land surface. Date May 13, 1972
Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 102 ft. Depth of completed well 101 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Topsoil	0	3	
Brown Clay	3	12	
Cemented Gravel	12	45	
Loose Gravel	45	70	12
Green Clay	70	98	
Coarse Sand + Gravel	98	102	8

Work started May 11 1972 Completed May 13 1972
Date well drilling machine moved off of well May 13 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Fraser (Drilling Machine Operator) Date May 15, 1972
Drilling Machine Operator's License No. 760

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Duffield Bros. (Person, firm or corporation) (Type or print)
Address 4123 Bluff SE Salem Ore
[Signed] Howard Duffield (Water Well Contractor)
Contractor's License No. 15 Date May 15, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119