

MAR 34 28

NC

RECEIVED WATER WELL REPORT JUN 18 1965 STATE ENGINEER SALEM, OREGON

Well no. 1
6/1w-27 C

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(1) OWNER: SALEM, OREGON

Name John Gerlets
Address 13523 35th Ave S
Seattle Washington

(2) LOCATION OF WELL:

County Marion Driller's well number
Bearing and distance from section or subdivision corner
2750 ft. west & 725 ft. south of N.E. corner of section 27, T.6 S, W. of W.M.

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded

10" Diam. from 1' above ft. to 217' 09" Gage 279
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used Mills Perforator
Size of perforations 3/4 in. by 3 in.
720 perforations from 110 ft. to 50 ft.
300 perforations from 216 ft. to 110 ft.
Bottom 100' - 2' perforations every 8" on N.E. side of R.W.P.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Clay & Bentonite
Depth of seal 18 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 15 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 29 ft. below land surface Date 11-28-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Drillers
Yield: 210 gal./min. with 81 ft. drawdown after 1 hr
" 220 " 172 " 7 "
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water X Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 10"

Depth drilled 258 ft. Depth of completed well 257 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL - brown	0	1
Clay - "	1	23
Course Conglom. - grey	23	30
Med. - " - " - hard	30	78
" Conglom. - grey - med hard	78	87
" " " " "	87	90
" " " " softer	90	99
" " " " med. hard	99	110
Packed med sand grey	110	116
Sandy clay - "	116	150
" " " "		
with layers of decayed wood	150	197
Sandy clay with scattered med. med. Gravel	197	215
Conglom. - grey - med hard	215	217
Clay - soft - sticky - light grey	217	235
" " " brown	235	245
" " " grey	245	258

Work started Oct. 14 1964. Completed Nov. 30 1964
Date well drilling machine moved off of well Nov. 30 1964

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. Stadel & Sons
(Person, firm or corporation) (Type or print)

Address Rte 3, Baxing, Silverton, Oregon

Drilling Machine Operator's License No. 164322

[Signed] Paul R. Stadel
(Water Well Contractor)

Contractor's License No. 296 Date 4-9 1965