

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

RECEIVED

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON

OCT 14 1981

State Well No.

65/w-28ab

(Please type or print)

WATER RESOURCES DEPT.

State Permit No.

(Do not write above this line)

SALEM, OREGON

(1) OWNER:

Name Bob Roth
Address 12513 Hobart Rd. NE
Silverton, Or 97381

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Driven
Jetted
Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
10" Diam. from +1 ft. to 332 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? Yes No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " " " " "
Air 500 " drill stem @ 575 "
er test gal./min. with ft. drawdown after hrs.
an flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 24' & 320-332 ft.
Diameter of well bore to bottom of seal 14" in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 18 sacks
How was cement grout placed? pumped
Was a drive shoe used? Yes No Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? dep of strata
Method of sealing strata cf
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
NW 1/4 SW 1/4 Section 28 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 56 ft.
Static level 29 ft. below land surface. Date 10/1/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 575 ft. Depth of completed well 575 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil med brn	0	2	
Clay med brn	2	14	
Clay med gray	14	32	
Congl. med gray	32	56	
Sand med-fine gray-blk	56	61	
Gravel, clay binder, gry	61	78	
Conglomerate, large, gry	78	122	
Clay med gray	122	178	
Clay med brn	178	252	
Clay med gray	252	306	
Sandstone med green	306	322	
Basalt med blk	322	332	
Basalt hrd gray	332	541	
Claystone hrd green	541	552	WB
Basalt med gray	552	575	WB

Work started 9/24 19 81 Completed 10/1 19 81
Date well drilling machine moved off of well 10/1 19 81

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dyson B. Stadel Date 10/6, 1981
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1371

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name West Coast Drilling Co., Inc.
(Person, firm or corporation) (Type or print)

Address 220 Academy St. Mt. Angel, Or.

[Signed] Charles E. Stadel
(Water Well Contractor)

Contractor's License No. 519 Date 10/6, 1981