

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JUL 10 1964
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

3451
MAR 11 1964

State Well No. 6/1W-28

State Permit No.

(1) OWNER:

Name Tony Schultz
Address Rt. 2, Box 67A
Silverton, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section 28 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Drill Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
4 " Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4-3/8
Gravel placed from 20 ft. to 147 ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 30 ft. below land surface Date 6-6-64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" 400 + Det. Lift " 80 P.L. approx.
" " " " "
Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 147 ft. Depth of completed well 0 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
surface & hard brown	0	40
gravel & clay hard	40	48
layers of clay & gravel	48	71
gravel & sand black	71	76
gravel & clay brown	76	84
gravel and sand hard brown	84	91
gravel and gray clay hard	91	98
sand black	98	104
gravel and clay	104	112
pea gravel and sand black	112	115
very hard cement gravel	115	121
blue clay	121	142
brown sand very fine	142	147

This 8" hole drilled about 2' North of 12" hole
It was for gravel feed and pulled completely out

Work started 4-28 19 64 Completed 8-10 19 64
Date well drilling machine moved off of well 6-10 19 64

(13) PUMP:

Manufacturer's Name Universal
Type: Turbine H.P. 40

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider Equipment Co.
(Person, firm or corporation) (Type or print)
Address Star Rt., Box 97, St. Paul, Oregon

Drilling Machine Operator's License No. 85

[Signed] Milo Schneider
(Water Well Contractor)

Contractor's License No. 387 Date 7-8, 19 64