

MARION 3471

OBSERVATION WELL
WATER WELL REPORT

6/1w-28 F(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

Tony Schantz

STATE OF OREGON

62246

State Well No.

State Permit No.

(1) OWNER:

Name OSCAR OVERLUND
Address Rt 2, Box 67
SILVERTON, ORE.

(2) LOCATION OF WELL:

County MARION Owner's number, if any—
¼ Section 2.8 T. 6.5 R. 1 W W.M.
Bearing and distance from section or subdivision corner
S 58° 15' W - 1304' NE
CR. DIC. CLAIM # 43.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
1 1/2" Diam. from _____ ft. to 162 ft. Gage 5/16
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used DRIVE DOWN 4 WAY.
SIZE of perforations in. by in.
6/2 perforations from 75 ft. to 118 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 2.5 ft.
Material used in seal— CLAY
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 31 ft. below land surface Date 12-15-61
Artesian pressure _____ lbs. per square inch Date _____
Log Accepted by: _____
[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? BECKERS
Yield: 4.50 gal./min. with 57 ft. drawdown after 15 hrs.
" " " " "
" " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 12 inches.
Depth drilled 192 ft. Depth of completed well _____ ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	25
BLUE CLAY	25	38
LARGE BOULDERS AND GRAVEL	38	48
CEMENTED SAND AND GRAVEL	48	118
BLUE CLAY	118	150
FINE SAND WITH WATER	150	158
BLUE CLAY WITH SMALL STREAKS OF SAND	158	192
SEE RECONDITIONING 7-21-62		

Work started OCT 31, 19 61 Completed 12-15-19 61

(13) PUMP:

120' of Column 6 inch Plus intak.
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLIAM J. STENNETT.
(Person, firm, or corporation) (Type or print)
Address 361 WARNER MILNE RD.
OREGON CITY, ORE.
Driller's well number _____
[Signed] William J. Stennett
(Well Driller)
License No. 5 Date 12-15, 19 61