

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No. 4s/1w-8 bd
State Permit No. _____

350
MARI.....

6-22

(1) OWNER:

Name AKATY KONEV
Address 875 BROWN RD
WOODBURN, OR

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

8" Diam. from 0 ft. to 172 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used STAR
Size of perforations 1 1/2 in. by 3/8 in.
225 perforations from 150 ft. to 165 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: 180 gal./min. with 46 ft. drawdown after 6 hrs.
250 " 90 " " " "
" " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water 51 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 28 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 24 sacks
How was cement grout placed? PUMPED

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County MARION Driller's well number _____
SE 1/4 NW 1/4 Section 8 T. 4S R. 1W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 21 ft.
Static level 60 ft. below land surface. Date 6/30/79
Artesian pressure lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 172 ft. Depth of completed well 172 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOPSOIL	0	3	
CLAY BROWN	3	21	
SILT BROWN	21	23	12
CLAY BLUE	23	52	
CLAY BROWN	52	63	
SILT BROWN	63	72	
SAND BROWN	72	84	55
SILT BROWN	84	89	
SANDSTONE BROWN	89	92	55
CEMENT GRAVEL GREY	92	105	
CLAY BLUE	105	130	
GRAVEL & SAND	130	168	60
CLAY GREY	168	172	

Work started 6/26/ 1979 Completed 6/30/ 1979
Date well drilling machine moved off of well 6/30/ 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Richard Beck Date 6/30/ 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1200

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name John W Beck Well Drilling
(Person, firm or corporation) (Type or print)

Address 24437 S. Kylan Dr. Canby, Ore.

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. 449 Date 6-30, 1979