NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

State Well No. 6/1W- 23 25

filed with the STATE OF OREGON STATE ENGINEER, SALEM, OREGOS BATE ENGINEER ype or print) within 30 days from the date of well completion.

SALEM. OREGON Write above this line)

State Permit No. G-4477

(1) OWNER:	(11) LOCATION OF WELL:
Name Albert Scharer	County Marion Driller's well number
Address Route 3. Silverton, Ore.	1/4 1/4 Section T. R. W.M
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well Deepening Reconditioning Abandon If abandonment, describe material and procedure in Item 12.	XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX
	of S.W. cor of sec 29 R.IW. T.6S.
Rotary D Driven D	(12) WELL LOG: Diameter of well below casingQ
Cable 1 Jetted Domestic Industrial Municipal Dug Bored Irrigation Test Well Other	Depth drilled 168 270t. Depth of completed well 166 ft.
	Formation: Describe color, texture, grain size and structure of materials:
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratum and aquifer penetrated.
	with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.
" Diam. from ft. to ft. Gage	MATERIAL From To SWL
	Top soil brn. 0 2
PERFORATIONS: Perforated? Yes No.	Clay brn. 2 30
Type of perforator used Mills knife	Clay grey 30 66
2/0	Sand grey fine. 66 69
Size of perforations 3/0 in. by 3 in. **The Original Control of the Control of t	Clay blue. 69 74
1600 perforations from 80 ft. to 160 ft.	Loose gravel & sand
perforations fromft. toft.	Med grey. W.B. 74 80
perforations from ft. to ft.	Conglom grey med. W.B. 80 I05
perforations from ft. to ft.	Losse gravel & sand
(7) CODERAIS.	Conglom course grey.W.B. IIO I48
(7) SCREENS: Well screen installed? Yes XNo	Loose sand & gravel
Manufacturer's Name	grey, course, grey.W.B. I48 I53
Diam. Slot size Set from ft. to ft.	Conglom course grey. 153 163
Diam. Slot size Set from ft. to ft.	Sand grey med. packed. I63 I67
	Clay grey. 167 172
(8) WATER LEVEL: Completed well.	Clay grey green. I72 215
state level 29 g ft. below land surface Date 5-28-68	070-
A lan pressure lbs. per square inch Date	Clay grey hard. 230 270
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	Test Hole) 6"
Was a pump test made? X Yes \(\sigma \) No \(\text{if yes, by whom?} \) Driller	Drilled to 270. filled back to 166 with bentonite & cutting.
100 T30 6	Work started 5-8-68 19 Completed 5-28-68 19
gai./min. with 100 ft. drawdown after 6 hrs.	Date well drilling machine mount of the well drilling machine mount of
	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported above are true to my hest
Artesian flow g.p.m. Date	Anowiedge and belief.
Temperature of water X Was a chemical analysis made? Yes X No	[Signed Date 6-I-68, 19
(10) CONSTRUCTION:	
Well seal—Material used Bentobite	Drilling Machine Operator's License No. 322
Depth of seal 20	Water Well Contractor's Certification:
Diameter of well bore to bottom of seal in.	This well was drilled under my jurisdiction and this rement is
Were any loose strata cemented off? Tes X No Depth	D. Chodold & Cons
Was a drive shoe used? ₩ Yes □ No	NAME R. DURGETT & DONS (Person, firm or corporation) (Type or print)
Did any strata contain unusable water?	Address Reute 3, Box I69, Silverton, Ore
Type of water? depth of strata	
Method of sealing strata off	[Signed] Saul J. Stadeli
Was well gravel packed? ☐ Yes No Size of gravel:	(Water Well Contractor)
Gravel placed from ft to ft.	Contractor's License No. 296 Date 6-24 1968
(USE ADDITIONAL SHEETS IF NECESSARY)	