

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
STATE OF OREGON
 JUN 27 1969
 STATE ENGINEER
 SALEM, OREGON

3506
 MAR 1 1969

State Well No. 6/1W-30
 State Permit No. _____

(1) OWNER:

Name LYNN SCHAAP
 Address RT 2 - SILVARTON ORR.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 8" Diam. from 7.1 ft. to 16.8 ft. Gage .250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No.
 Type of perforator used bits
 Size of perforations 1/2 in. by 2 in.
 _____ perforations from _____ ft. to _____ ft.
786 perforations from 10.0 ft. to 16.5 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 30 ft. below land surface Date 5-2-69
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom? Robinson West
 Yield: 320 gal./min. with 110 ft. drawdown after 35 hrs.
265 " " 75 " " 15 "
225 " " 50 " " 3 "

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used DRILLING CLAY + BENTONITE
 Depth of seal 40 ft.
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County WAGON Driller's well number _____
 1/4 Section 30 T. 6,8 R. 1, W W.M.
 Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 167 ft. Depth of completed well 167 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
BROWN - CLAY	0	12	
" " (SANDY)	12	38	
BROWN - SAND	38	61	
(CRACKED)			
BROWN - CEMENTED	61	93	
GRAVEL			
MED. SAND	93	103	
+ GRAVEL			
BROWN - CEMENTED	103	155	
GRAVEL			
BROWN - SAND + GRAVEL	155	161	
(CRACKED)			
BROWN - CEMENTED	161	167	
GRAVEL			

Work started 4-24-1969 Completed 5-7-1969
 Date well drilling machine moved off of well 5-8-1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] W. M. ... Date May 8 1969
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Miller - Robinson West
 (Person, firm or corporation) (Type or print)

Address 5545 Joseph St. S.E. SALEM

[Signed] Walter R. Miller
 (Water Well Contractor)

Contractor's License No. 37 Date 5-8, 1969