

(1) OWNER: **STATE ENGINEER**
Name OSCAR STRAND
Address RT-2 BOX 127 SILVERTON OREG.

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
SE 1/4 SE 1/4 Section 33 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner
2129' S & 466.5' E from NW COR
DAVIS DUG #6

TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Agricultural Industrial Municipal
Domestic Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from 1 ft. to 60' 10" ft. Gage 4
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used NONE
SIZE of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

SCREENS:
Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Gravel packed? Yes No Size of gravel: _____
placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 10" + ft.
Material used in seal— PUMP
Did any strata contain unusable water? Yes No
Type of water? GOOD Depth of strata 68'
Method of sealing strata off BACK FILL

(10) WATER LEVELS:
Static level 19' 6" ft. below land surface Date 8-15-57
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] Oscar Strand Date Sept 9, 1957
(Owner)

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 60 gal./min. with 38 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 56° Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well 8' 1-0 inches.
Depth drilled 71' 5" ft. Depth of completed well 71' 5" ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOPSOIL	2	2
CLAY YELLOW COLOR	22	24
CEMENTED GRAVEL YELLOW	26	26
CEMENTED GRAVEL BLUE	4	30
SANDY CLAY BLUE	7	37
CEMENTED GRAVEL BLUE	10	47
CLAY GRAY COLOR	5	52
CEMENTED GRAVEL YELLOW	8	60
BASEALT ROCK	115	71' 5"

Work started 8-14 1957 Completed 8-15 1957

(13) PUMP:
Manufacturer's Name Myers
Type: jet H.P. 1/2

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED & SONS
(Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST SALEM, O.
Driller's well number _____
[Signed] J. A. Sneed
(Well Driller)
License No. 6 Date 8-19, 1957