

RECEIVED
JAN 27 1961

RECEIVED
MAY 11 1961

M 1R1... 3581

6/1W-30E(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

STATEWIDE REPORT
OREGON
G-4133
G-2007

State Well No. _____
State Permit No. _____

(1) OWNER:
Name LEROY BEALS
Address RT. 2 Box 204H. SILVERTON ORE

WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STYLER SUPPLY
Yield: 750 gal./min. with 41 ft. drawdown after 1 hrs.
" 430 " 24 " 1 "
" 275 " 12 " 1/2 "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 55° Was a chemical analysis made? Yes No

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
1/4 Section 30 T. 6 R. 1W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well 8" inches.
Depth drilled 149' ft. Depth of completed well 149' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from 0 ft. to 149' ft. Gage 24"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

MATERIAL	FROM	TO
TOPSOIL	0	2
YELLOW CLAY	2	18
BLUE CLAY SANDY	18	48
BLUE CLAY STICKY	48	58
BLUE CLAY SANDY	58	65
SAND FINE GRITTY	65	72
CEMENTED GRAVEL	72	77.6
BLUE CLAY SANDY	77.6	84.6
CEMENTED GRAVEL	84.6	94
WATER GRAVEL	94	95
CEMENTED GRAVEL	95	100
WATER GRAVEL #2"	100	102
CEMENTED GRAVEL	102	140
YELLOW CLAY	140	142
CEMENTED GRAVEL	142	149

(7) PERFORATIONS:
Type of perforator used _____
Perforated? Yes No
SIZE of perforations 3/16 in. by 2" in.
700 perforations from 90 ft. to 142' ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 8" ft.
Material used in seal—TO BE COVERED BY PUMP
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 30' ft. below land surface Date 12-26
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] Le Roy Beals Date 12-14, 1960
(Owner)

Work started 12-5-1960 Completed 12-12-1960

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. A. SNEED + SONS
(Person, firm, or corporation) (Type or print)
Address 2505 BROOKS ST. SALMON ORE

Driller's well number _____
[Signed] J. A. Sneed
(Well Driller)
License No. 6 Date 12-12-1960