

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No.

State Permit No.

WELL #2

(1) OWNER:

Name Marcium Samoilov
Address 5870 Valley View Rd.
Silverton, OR 97381

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Cable ☐
Driven ☐ Jetted ☐
Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
8" Diam. from +1 ft. to 20 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

gal./min. with ft. drawdown after hrs.
" " "
" " "
Air 100 gal./min. with 400 ft. drawdown after 1 1/2 hrs.
Bailer test
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? Pressure

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number
NE 1/4 NE 1/4 Section 36 T. 6S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 456 ft.
Static level 75 ft. below land surface. Date 10/29/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 511 ft. Depth of completed well 511 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil Brown	0	1	
Clay Brown Soft	1	12	
Sandstone Grey Hard	12	210	
Sandstone Blue Medium	210	215	
Conglomerate Sedimentary			
Brecca	215	245	
Sandstone Blue Medium	245	290	
Sandstone Grey Medium	290	349	
Conglomerate Sedimentary			
Brecca	349	429	
Grey Sandstone	429	469	
Fine Sand White	469	484	
Grey Sandstone	484	511	

RECEIVED

RECEIVED

APR 21 1980

AUG 25 1980

WATER RESOURCES DEPT WATER RESOURCES DEPT
SALEM, OREGON SALEM, OREGON

Work started 10-23 1979 Completed 10-29 1979
Date well drilling machine moved off of well 10-30 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] John McElwain Date 12-15, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1390

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name WEST COAST DRILLING CO
(Person, firm or corporation) (Type or print)

Address 220 Academy St. Mt. Angel OR 97362

[Signed] Charles E. Stedeh
(Water Well Contractor)

Contractor's License No. 519 Date 12-15, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)