

RECEIVED

MAR 3 7 08

T-175?? 175 62W-1

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

MAR 23 1962

WATER WELL REPORT

State Well No. _____

STATE OF OREGON

State Permit No. _____

(1) OWNER:

Name CLARENCE D. HERR
Address RT. 2 BOX 188 SILVERTON OREGON

(2) LOCATION OF WELL:

County MARION Owner's number, if any -
1/4 Section 1 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [] Deepening [x] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 134' ft. Gage 32"
8" Diam. from 134 ft. to 200 ft. Gage 24"
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [x] Yes [] No
Type of perforator used MILLS type
SIZE of perforations 2 in. by 1/16 in.
400 perforations from 90 ft. to 130 ft.
400 perforations from 135 ft. to 164 ft.

(8) SCREENS:

Well screen installed [] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [x] Yes [] No Size of gravel:
Gravel placed from 60 ft. to 90 ft.
Was a surface seal provided? [x] Yes [] No To what depth? 10" ft.
Material used in seal - PUMP COVERED
Did any strata contain unusable water? [] Yes [x] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 41' ft. below Jan/surface Date 3-20-62
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Clarence D. Herr Date 3/20, 1962 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [] No If yes, by whom?
Yield: 320 gal./min. with 40 ft. drawdown after 5 hrs.
470 " 67 " 1 "
500 " 84 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well 10" to 8" inches.
Depth drilled 200 ft. Depth of completed well 200' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Contains handwritten entries: SEE ORIGINAL RECORD, ORIGINAL DEPTH, CONGLOMERATE W.B. 134' 164', BLUE CLAY STICKY 164' 175', BLUE CLAY SANDY W.B. 175' 190', BLUE CLAY STICKY 190' 200'. Includes note: 8" LINER SET AT 134' AND DRILLED TO 200'.

Work started 3-13-62 Completed 3-20-1962

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.A. SNEED + SONS (Person, firm, or corporation) (Type or print)

Address 3910 SILVERTON RD. SALAM ORE

Driller's well number

[Signed] J.A. Sneed (Well Driller)

License No. 6 Date 3-20-1962


J. A. SNEED & SONS

WELL DRILLING CONTRACTORS

~~2505 Brooks Street~~ Phone 3-6809

SALEM, OREGON

3910 SILVERTON ROAD, N.E.



State Engineer
Salem, Ore.

3-20-62

Inclosed please find well record report
for well-10" which we completed 3-20-62
for Clarence D. Hess. Pt. 2 Box 188
Silverton Ore.

This well from Mr. Hess's information
has been registered at your office.
However we have deepened it to secure
more water as the well in recent years
has depleted from 270 G.P.M. down to 170
Our operation was to set an 8" casing
to the bottom of 134' through a 10" casing
and deepening to 200' - the 8" casing has
been cut off at 131'

The well pump has not been installed
but the owner will inform your office
the name, type and H.P. as soon as
he has completed the arrangements for same.
Yours Truly
B. J. Sneed