

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

RECEIVED
APR 14 1970
STATE ENGINEER
SALEM, OREGON

MAR 31 1970
RECEIVED
APR 20 1970
STATE ENGINEER
SALEM, OREGON

Well No. 6/2W-2bc
65204

(1) OWNER:

Name Moses M. Palma
Address 7606 Wabash Drive NE Brooks, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from top ft. to 180 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used Mills
Size of perforations 2 in. by 3/8 in.
260 perforations from 110 ft. to 130 ft.
100 perforations from 170 ft. to 179 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 27 ft. below land surface Date 4-8-70
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 300 gal./min. with 10 ft. drawdown after 4 hrs.
400 " " 13 " " 4 "
" 500 " " 18 " " 4 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Cement and Puddle Clay
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Marion Driller's well number 1469
1/4 Section 2 T. 6S R. 5E 2W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing

Depth drilled 180 ft. Depth of completed well 180 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Yellow Clay	2	40	
Blue clay	40	70	
Black sand	70	80	
Blue clay	80	107	
Gravel	107	133	
Gray clay	133	145	
Black sand	145	152	
Blue clay	152	160	
Black sand	160	165	
Gravel	164	180	

Work started March 30, 1970 Completed April 9, 1970

Date well drilling machine moved off of well April 10, 1970

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ronald W. Norton Date 4-9-70, 19...
(Drilling Machine Operator)

Drilling Machine Operator's License 536

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING COMPANY
(Person, firm or corporation) (Type or print)

Address 7641 35th Ave. NE Salem, Oregon 97303

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date 4-10-70, 19...