

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED MARI... 3726
WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 MAY 10 1965 STATE OF OREGON
within 30 days from the date of well completion. (Please type or print)

State Well No. 6/2w-2 B1

State Permit No. _____

(1) OWNER:

Name JOHN ZELLNER
Address RT. 1 BOX 150
GERVAIS, OREGON

STATE ENGINEER
SALEM OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number I020
1/4 Section 2 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
I2 " Diam. from TOP ft. to I95 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 1/2 in. by 2 1/2 in.
168 perforations from I25 ft. to I35 ft.
300 perforations from I75 ft. to I95 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used? _____
Diameter of well bore to bottom of seal I4 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 30 ft. below land surface Date 4/17/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 700 gal./min. with 38 ft. drawdown after 16 hrs.
" 500 " " 22 " " 16 "
" 500 " " 20 " " 16 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled I95 ft. Depth of completed well I95 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	15
YELLOW SANDY CLAY	15	44
BLUE SHALE	44	70
SANDY BLUE SHALE	70	83
STICKY BLUE SHALE	83	100
HARD GRITTY BLACK SHALE	100	122
BLACK SAND & GRAVEL	122	135
BLACK SAND & GRAVEL	135	135
BLACK SHALE	135	140
BLACK SANDY SHALE	140	158
BLACK SAND	158	170
BLACK SAND & GRAVEL	170	195
GRAYISH BLACK SAND SHALE	195	?

Work started MAR. 19 1965 Completed APRIL 17 1965
Date well drilling machine moved off of well APRIL 17 1965

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 74

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date APRIL 17 1965