

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

3727
 MARI...

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

State Well No. 6/zw-2 A01
 State Permit No. _____

G2376

(1) OWNER:
 Name John Zeilner
 Address Rt 1 Box 150
Gervais

(2) LOCATION OF WELL:
 County MARION Driller's well number _____
NE 1/4 NE 1/4 Section 2 T. 6S R. 2W W.M.
 Bearing and distance from section or subdivision corner
S 5° 50' W - 910' from NE
Corner Section 2,

(3) TYPE OF WORK (check):
 Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL: Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from 0 ft. to 120 ft. Gage _____
 _____" Diam. from _____ ft. to _____ ft. Gage _____
 _____" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
 Manufacturer's Name _____
 Model No. _____
 _____ Slot size Set from _____ ft. to _____ ft.
 _____ Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal _____
 Depth of seal _____ ft. Was a packer used? Yes No
 Diameter of well bore to bottom of seal _____ in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 25.90 ft. below land surface Date 1-12-60
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 200 gal./min. with 48 ft. drawdown after _____ hrs.
 " 400 " at 79 " _____ "
 " 600 " at 114 " _____ "
 Bailor test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
 Depth drilled _____ ft. Depth of completed well _____ ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	20
Sandy clay	20	60
Black sand	60	80
Gray sand and clay	80	105
Cemented gravel	105	109
Loose gravel	109	112
Cemented gravel	112	115
Gray sand	115	118
Loose gravel	118	122
Cemented gravel	122	125

Data from Application File

Work started _____ 19 _____ Completed _____ 19 54
 Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:
 Manufacturer's Name _____
 Type: Turbine H.P. 30 HP

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME _____ (Person, firm or corporation) (Type or print)
 Address _____
 Drilling Machine Operator's License No. _____
 [Signed] _____ (Water Well Contractor)
 Contractor's License No. _____ Date _____, 19 _____