

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
 MAR 11 1965
 WATER WELL REPORT
 STATE ENGINEER
 SALEM, OREGON

State Well No. 6/2w-3F

State Permit No. G3078

(1) OWNER:

Name Edwin C. Johnson
 Address Rt. 1 Box 81F
Brooks, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 6/2W-3E
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12 3/4 Diam. from 140 ft. to 139 1/2 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used Mills
 Size of perforations 5/16 in. by 2 1/2 in.
 perforations from 114 ft. to 138 ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite & drillings
 Depth of seal 18 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 15 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusuable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 3/20/65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler
 Yield: 450 gal./min. with 80 ft. drawdown after 1 hrs.
 " 500 " 80 " 2 "
 " 550 " 110 " 1 "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date _____

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	2
Yellow clay	2	12
Yellow silt	12	30
Grey silt	30	62
Blk muddy sand	62	81
Clean blk sand	81	87
Grey clay	87	98
Gravel with clay	98	112
clean sand & gravel	112	138
Blue grey clay	138	140

Work started 3/11/65 19 Completed 3/20/65 19
 Date well drilling machine moved off of well 3/20/65 19

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson
 (Person, firm or corporation) (Type or print)
 Address 2214 Front St. NE Salem, Ore.

Drilling Machine Operator's License No. 63

[Signed] Harry A. Robinson
 (Water Well Contractor)
 Contractor's License No. 22 Date 3/22/65, 19____