

Well #2

MARI. 3787

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT MAY 10 1967 STATE ENGINEER (Please type or print) G-3933

State Well No. 6/2w-4c State Permit No.

(1) OWNER:

Name FRED GOLDSMITH S.W. OAK STREET Address PORTLAND, OREGON 97223

(2) LOCATION OF WELL:

County MARION Driller's well number I211 1/4 Section 4 T. 6 R. 2 W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from Top 210 ft. to 210 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used MILLS Size of perforations 2 in. by 3/8 in. 570 perforations from 182 ft. to 210 ft. 310 perforations from 120 ft. to 137 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY Depth of seal 20 ft. Was a packer used? Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 23 ft. below land surface Date 5/4/67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER Yield: 550 gal./min. with 23 ft. drawdown after 29 hrs. " 500 " " 21 " 29 " " 450 " " 19 " 29 " 400 gal./min. with 16 ft. drawdown after 29 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 210 ft. Depth of completed well 210 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include TOP SOIL, yellow CLAY, BROWN CLAY, GRAY CLAY, BLACK SAND, GRAY CLAY & SMALL GRAVEL, BLACK SAND & CEMENTED GRAVEL, GRAY CLAY & GRAVEL, GRAY CLAY, BLACK SAND, GRAY CLAY, BLACK SAND & GRAVEL.

Work started NOV. 21 1966 Completed MAY 4 1967 Date well drilling machine moved off of well MAY 4 1967 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO (Person, firm or corporation) (Type or print) Address RT. 2 BOX 276 SALEM 97393 Drilling Machine Operator's License No. 474 [Signed] Emil O. Beier (Water Well Contractor) Contractor's License No. 2 Date MAY 4 1967, 19