

Well #1

RECEIVED

MAR 3 1969

DEC 12 1966

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE ENGINEER SALEM, OREGON
(Please type or print) SALEM, OREGON

G-3933

State Well No. 6/2w-44
State Permit No.

(1) OWNER:

Name FRED GOLDSMITH
Address 6611 S.W. OAK STREET
PORTLAND, OREGON ZIP 97233

(2) LOCATION OF WELL:

County MARION Driller's well number I184
1/4 Section 4 T. 6 S R. 2 W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug
Driven Jetted Bored

(6) CASING INSTALLED:

10" Diam. from TOP ft. to 200 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used MILLS
Size of perforations 2 in. by 3/8 in.
230 perforations from ft. to ft.
200 perforations from 125 ft. to 135 ft.
perforations from 185 ft. to 200 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 30 ft. below land surface Date II. 17/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 500 gal./min. with 31 57 drawdown after 12 hrs.
" 455 450 " 47 " 12 "
" 400 " 43 " 12 "
Pump test 350 gal./min. with 35ft. drawdown after 12 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing
Depth drilled 200 ft. Depth of completed well 200 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	3
YELLOW CLAY	3	18
BROWN CLAY	16	35
GRAY CLAY	35	75
BLACK SAND	75	120
CEMENTED BLACK SAND & GRAVEL	120	136
GRAY CLAY	136	160
BLACK SAND	160	180
BLACK SAND & GRAVEL	180	200

Work started OCT 10 1966 Completed NOV 17 1966
Date well drilling machine moved off of well NOV 17 1966₁₉

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
(Person, firm or corporation) (Type or print)
Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 474

[Signed] Emil O. Beier
(Water Well Contractor)

Contractor's License No. 2 Date NOV 17 1966₁₉