

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MARI. 3798
 WATER WELL REPORT
 JUL 23 1965
 STATE ENGINEER
 (Please type or print) G-3213
 G 3280

State Well No. 6/2w-5 F1

State Permit No. _____

(1) OWNER: SALEM OREGON

Name Oak Crest Farm
 Address 2770 Wallace Rd NW
Salem, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 6/2W-5F
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded

12 3/4 Diam. from 140 ft. to 221 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No

Type of perforator used Mills
 Size of perforations 5/16 in. by 2 1/8 in.
180 perforations from 124 1/2 ft. to 144 ft.
528 perforations from 197 1/2 ft. to 219 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No

Manufacturer's Name _____ Type _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 _____ Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
 Depth of seal 18 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusuable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 33 ft. below land surface Date 7/13/65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Stettler
 Yield: 600 gal./min. with 29 ft. drawdown after 2 1/2 hrs.
 " 500 " " 22 " 1 "
 " " " " "

Ballor test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 12

Depth drilled 221 ft. Depth of completed well 221 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	1
Yellow clay	1	15
Yellow silty clay	15	35
Blue silty clay	35	70
Muddy blk sand	70	83
Clean coarse sand	83	93
Clean sand & gravel	93	105
Muddy blk sand	105	115
Sand & gravel	115	123
Clean brwn sand & gravel	123	143
Gravel with clay	143	145
Sticky blue clay	145	157
Clean blk sand	157	168
Blue sticky clay	168	184
Fine blk sand with rotted vegetation	184	186
Clean blk sand with few gravels	186	193
Sand & gravel	193	200
Muddy sand	200	201
Clean sand	201	203
Clean sand & gravel	203	221

Work started 6/26/65 19 Completed 7/13/65 19
 Date well drilling machine moved off of well _____ 19

(13) PUMP:

Manufacturer's Name _____ Type _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Harry A. Robinson (Person, firm or corporation) (Type or print)

Address 2214 Front St. NE Salem, Ore.

Drilling Machine Operator's License No. 63

[Signed] Harry A. Robinson (Water Well Contractor)

Contractor's License No. 22 Date 7/22/65, 19